

West Gregg Special Utility District  
P.O. Box 1196  
Kilgore, TX 75663  
903-983-1816 Fax 903-984-0707

## INSPECTIONS

- Inspections are done Monday – Friday, 8 am – 4 pm
- Inspections require at least a 24 hour notice
- A hose bib vacuum breaker is required on each exterior faucet
- Each exterior faucet must indicate that it does not contain lead
- We may require access to the interior of your home to look at the water heater
- If an additional inspection trip is required, an additional \$30 inspection fee will be charged.

### What Our Inspectors Will Be Looking For

- No direct or indirect connection between the public drinking water supply and a potential source of contamination exists. Potential sources of contamination are isolated from the public water system by an air gap or an appropriate backflow prevention assembly in accordance with Commission regulations.
- 
- No cross-connection between the public drinking water supply and a private water system exists. Where an actual air gap is not maintained between the public water supply and a private water supply, an approved reduced pressure principle backflow prevention assembly is properly installed.
- No connection exists which would allow the return of water used for condensing, cooling or industrial processes back to the public water supply.
- No pipe or pipe fitting which contains more than 8.0% lead exists in private water distribution facilities installed on or after July 1, 1988 and prior to January 4, 2014.
- Plumbing installed on or after January 4, 2014 bears the expected labeling indicating  $\leq 0.25\%$  lead content. If not properly labeled, please provide written comment.
- No solder or flux which contains more than 0.2% lead exists in private water distribution facilities installed on or after July 1, 1988.

I have read the information printed on this sheet and accept the requirements and stipulations therein.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date